

Armstrong Richardson & Co Ltd Portable Appliance Test Results

Premises: **AR ENTERTAINMENTS**

Date tested: **1/2/17**

Re-test Date: **1/2/18**

ARB

App. No.	Description	Class	Visual				Earth Continuity (n/a class 2)	Insulation	Polarity	Result P - Pass F - Fail
			Cable	App.	Plug Ext	Plug Int				
115	Plug Converter	B	✓	✓	✓	✓	3	0.095	✓	✓
116	"	B	✓	✓	✓	✓	3	0.085	✓	✓
117	"	B	✓	✓	✓	✓	3	0.087	✓	✓
118	"	B	✓	✓	✓	✓	3	0.081	✓	✓
119	"	B	✓	✓	✓	✓	3	0.079	✓	✓
120	"	B	✓	✓	✓	✓	3	0.089	✓	✓
121	"	B	✓	✓	✓	✓	3	0.074	✓	✓
122	"	B	✓	✓	✓	✓	3	0.075	✓	✓
123	"	B	✓	✓	✓	✓	3	0.086	✓	✓
124	"	B	✓	✓	✓	✓	3	0.089	✓	✓
125	"	B	✓	✓	✓	✓	3	0.047	✓	✓
126	"	B	✓	✓	✓	✓	3	0.030	✓	✓
127	"	B	✓	✓	✓	✓	3	0.090	✓	✓
128	"	B	✓	✓	✓	✓	3	0.091	✓	✓
129	"	B	✓	✓	✓	✓	3	0.034	✓	✓
130	"	B	✓	✓	✓	✓	3	0.045	✓	✓
131	"	B	✓	✓	✓	✓	3	0.034	✓	✓
132	"	B	✓	✓	✓	✓	3	0.032	✓	✓
133	"	B	✓	✓	✓	✓	3	0.084	✓	✓
134	"	B	✓	✓	✓	✓	3	0.091	✓	✓
135	"	B	✓	✓	✓	✓	3	0.024	✓	✓
136	"	B	✓	✓	✓	✓	3	0.065	✓	✓
137	"	B	✓	✓	✓	✓	3	0.109	✓	✓
138	"	B	✓	✓	✓	✓	3	0.234	✓	✓
139	"	B	✓	✓	✓	✓	3	0.239	✓	✓
140	"	B	✓	✓	✓	✓	3	0.237	✓	✓
141	"	B	✓	✓	✓	✓	3	0.237	✓	✓
142	"	B	✓	✓	✓	✓	3	0.227	✓	✓
143	10mtr Ext	B	✓	✓	✓	✓	3	0.125	✓	✓
144	"	B	✓	✓	✓	✓	3	0.166	✓	✓
145	"	B	✓	✓	✓	✓	3	0.121	✓	✓
146	"	B	✓	✓	✓	✓	3	0.167	✓	✓
147	"	B	✓	✓	✓	✓	3	0.171	✓	✓
148	"	B	✓	✓	✓	✓	3	0.166	✓	✓
149	"	B	✓	✓	✓	✓	3	0.162	✓	✓
150	"	B	✓	✓	✓	✓	3	0.168	✓	✓
151	"	B	✓	✓	✓	✓	3	0.125	✓	✓
152	"	B	✓	✓	✓	✓	3	0.130	✓	✓
153	"	B	✓	✓	✓	✓	3	0.140	✓	✓
154	"	B	✓	✓	✓	✓	3	0.225	✓	✓
155	"	B	✓	✓	✓	✓	3	0.163	✓	✓
156	"	B	✓	✓	✓	✓	3	0.130	✓	✓
157	"	B	✓	✓	✓	✓	3	0.166	✓	✓
158	"	B	✓	✓	✓	✓	3	0.168	✓	✓
159	"	B	✓	✓	✓	✓	3	0.130	✓	✓
160	"	B	✓	✓	✓	✓	3	0.161	✓	✓
161	"	B	✓	✓	✓	✓	3	0.163	✓	✓
162	"	B	✓	✓	✓	✓	3	0.206	✓	✓
163	"	B	✓	✓	✓	✓	3	0.201	✓	✓
164	"	B	✓	✓	✓	✓	3	0.048	✓	✓
165	"	B	✓	✓	✓	✓	3	0.120	✓	✓
166	"	B	✓	✓	✓	✓	3	0.123	✓	✓
167	"	B	✓	✓	✓	✓	3	0.102	✓	✓
168	"	B	✓	✓	✓	✓	3	0.161	✓	✓
169	"	B	✓	✓	✓	✓	3	0.128	✓	✓
170	"	B	✓	✓	✓	✓	3	0.130	✓	✓
171	"	B	✓	✓	✓	✓	3	0.138	✓	✓

Armstrong Richardson & Co Ltd Portable Appliance Test Results

Premises: **AR ENTERTAINMENTS**

Date tested: **1/2/17**

Re-test Date: **1/2/18**

ARE

App. No.	Description	Class	Visual				Fuse	Earth Continuity (n/a class 2)	Insulation	Polarity	Result P - Pass F - Fail
			Cable	App.	Plug Ext	Plug Int					
172	10mt Ext.	1	0	0	0	0	1	0.156			P
173	"	1	0	0	0	0	1	0.132			P
174	"	1	0	0	0	0	1	0.130			P
175	"	1	0	0	0	0	1	0.140			P
176	"	1	0	0	0	0	1	0.167			P
178	"	1	0	0	0	0	1	0.166			P
177	14m Ext	1	0	0	0	0	1	0.172			P
179	"	1	0	0	0	0	1	0.167			P
180	"	1	0	0	0	0	1	0.135			P
181	"	1	0	0	0	0	1	0.170			P
182	"	1	0	0	0	0	1	0.171			P
183	"	1	0	0	0	0	1	0.174			P
184	25m Ext	1	0	0	0	0	1	0.190			P
185	"	1	0	0	0	0	1	0.192			P
186	"	1	0	0	0	0	1	0.189			P
187	"	1	0	0	0	0	1	0.189			P
188	"	1	0	0	0	0	1	0.186			P
189	"	1	0	0	0	0	1	0.190			P
190	"	1	0	0	0	0	1	0.190			P
191	"	1	0	0	0	0	1	0.298			P
192	"	1	0	0	0	0	1	0.237			P
193	"	1	0	0	0	0	1	0.264			P
194	"	1	0	0	0	0	1	0.164			P
195	"	1	0	0	0	0	1	0.258			P
196	"	1	0	0	0	0	1	0.295			P
197	"	1	0	0	0	0	1	0.242			P
198	"	1	0	0	0	0	1	0.297			P
199	"	1	0	0	0	0	1	0.283			P
200	"	1	0	0	0	0	1	0.297			P
201	"	1	0	0	0	0	1	0.295			P
202	"	1	0	0	0	0	1	0.298			P
203	"	1	0	0	0	0	1	0.289			P
204	"	1	0	0	0	0	1	0.295			P
205	"	1	0	0	0	0	1	0.295			P
206	"	1	0	0	0	0	1	0.245			P
207	"	1	0	0	0	0	1	0.280			P
208	long splitter	1	0	0	0	0	1	0.059			P
209	"	1	0	0	0	0	1	0.163			P
210	"	1	0	0	0	0	1	0.063			P
211	short splitter	1	0	0	0	0	1	0.153			P
212	"	1	0	0	0	0	1	0.020			P
213	"	1	0	0	0	0	1	0.018			P
214	"	1	0	0	0	0	1	0.019			P
215	"	1	0	0	0	0	1	0.015			P
216	"	1	0	0	0	0	1	0.019			P
217	3Way splitter	1	0	0	0	0	1	0.011			P
218	"	1	0	0	0	0	1	0.006			P
219	"	1	0	0	0	0	1	0.006			P
220	"	1	0	0	0	0	1	0.008			P
221	"	1	0	0	0	0	1	0.008			P
222	"	1	0	0	0	0	1	0.008			P
223	"	1	0	0	0	0	1	0.010			P
224	"	1	0	0	0	0	1	0.010			P
225	"	1	0	0	0	0	1	0.010			P
226	"	1	0	0	0	0	1	0.008			P
227	2way Reconnector	1	0	0	0	0	1	0.035			P
228	"	1	0	0	0	0	1	0.032			P

Armstrong Richardson & Co Ltd Portable Appliance Test Results

Premises: AR ENTERTAINMENTS

Date tested: 1/2/17

Re-test Date: 1/2/18

App. No.	Description	Class	Visual				Fuse	Earth Continuity (n/a class 2)	Insulation	Polarity	Result P - Pass F - Fail
			Cable	App.	Plug Ext	Plug Int					
229	2 way Reconnector	-	P	P	P	P	-	0.072			P
230	" "	-	P	P	P	P	-	0.081			P
231	"	-	P	P	P	P	-	0.133			P
232	"	-	P	P	P	P	-	0.085			P
233	"	-	P	P	P	P	-	0.071			P
234	Single Reconnector	-	P	P	P	P	-	0.158			P
235	4 way Surge	-	P	P	P	P	-	0.140			P
236	4 way Ext	-	P	P	P	P	13	0.166			P
237	" "	-	P	P	P	P	13	0.133			P
238	" "	-	P	P	P	P	13	0.192			P
239	2.0hp blower	-	P	P	P	P	-	0.175	>20		P
240	"	-	P	P	P	P	-	0.169	>20		P
241	"	-	P	P	P	P	-	0.135	>20		P
242	1 Shp Blower	-	P	P	P	P	-	0.085	>20		P
243	"	-	P	P	P	P	-	0.076	>20		P
244	"	-	P	P	P	P	-	0.056	>20		P
245	"	-	P	P	P	P	-	0.083	>20		P
246	"	-	P	P	P	P	-	0.078	>20		P
247	"	-	P	P	P	P	-	0.096	>20		P
248	"	-	P	P	P	P	-	0.089	>20		P
249	"	-	P	P	P	P	-	0.125	>20		P
250	"	-	P	P	P	P	-	0.165	>20		P
251	"	-	P	P	P	P	-	0.095	>20		P
252	"	-	P	P	P	P	-	0.125	>20		P
253	"	-	P	P	P	P	-	0.139	>20		P
254	"	-	P	P	P	P	-	0.054	>20		P
255	"	-	P	P	P	P	-	0.125	>20		P
256	"	-	P	P	P	P	-	0.085	>20		P
257	"	-	P	P	P	P	-	0.065	>20		P
258	"	-	P	P	P	P	-	0.055	>20		P
259	"	-	P	P	P	P	-	0.135	>20		P
260	"	-	P	P	P	P	-	0.125	>20		P
261	"	-	P	P	P	P	-	0.089	>20		P
262	"	-	P	P	P	P	-	0.178	>20		P
263	0.75 blower	-	P	P	P	P	-	0.195	>20		P
264	Melt down	-	P	P	P	P	-	0.225	>20		P
265	R. Bull	-	P	P	P	P	-	0.195	>20		P
266	Surf	-	P	P	P	P	-	0.215	>20		P
267	H/Roulette	-	P	P	P	P	-	0.275	>20		P
268	Wakka Mole fan	-	P	P	P	P	-	0.089	>20		P
269	Twist Air fan	-	P	P	P	P	-	0.275	>20		P
270	Golf Blower	-	P	P	P	P	-	0.225	>20		P
271	Fun guys	-	P	P	P	P	-	0.195	>20		P
272	Fun guys	-	P	P	P	P	-	0.195	>20		P
273	Circuit Breaker	-	P	P	P	P	-	0.055			P
274	"	-	P	P	P	P	-	0.065			P
275	"	-	P	P	P	P	-	0.081			P
276	"	-	P	P	P	P	-	0.59			P
278	"	-	P	P	P	P	-	0.45			P
279	"	-	P	P	P	P	-	0.75			P
277	"	-	P	P	P	P	-	0.89			P
280	CCTV	-	P	P	P	P	-		>20		P
281	CCTV	-	P	P	P	P	-		>20		P
282	10m plug Connector	-	P	P	P	P	13	0.295			P
283	"	-	P	P	P	P	13	0.295			P
284	"	-	P	P	P	P	13	0.285			P

ARE.

Polarity

Result