Armstrong Richardson & Co Ltd Portable Appliance Test Results

Premises: AR Entertainments Date tested: 16/2/17 Re-test Date: 16/2/18

ARE		Class	Visual					Earth	Insulation	Polarity	Result
App. No.	Description		Cable	App.	Plug Ext	Plug Int	Fuse	Continuity (n/a class 2)			P - Pass F - Fail
285	2.0hp Blower	I	P	P	P	P		0.043	>20		P
286	2.0hp Blower	I	P	P	P	P		0.046	>20		P
287	1.5hp Blower	I	P	P	P	P		0.036	>20		P
288	1.5hp Blower	I	P	P	P	P		0.032	>20		P
289	Plug convertor		P	P	P	P	13	0.038		P	P
290	Plug convertor		P	P	P	P	13	0.027		P	P
291	Plug convertor		P	P	P	P	13	0.026		P	P
292	Plug convertor		P	P	P	P	13	0.031		P	P