

Risk Assessment For
 AR Entertainment's
 Mount Pleasant Way
 Stokesley Business Park
 Stokesley North Yorkshire
 TS9 5NZ

ASSESSMENT UNDERTAKEN
 Date..... 02/03/2017
 Signed..... *Ray Dunn*
 Equipment.....Generator/ Petrol Blowers

ASSESSMENT REVIEW
 1st.....
 2nd.....
 3rd.....
 4th.....

The Siting of a Generator or Petrol Blower must be in a safe/level and stable position and fenced off.
All Generators to be earthed using an earth rod.

| <u>LIST OF SIGNIFICANT HAZARDS</u> | <u>GROUPS AT RISK</u> | <u>EXISTING CONTROLS covered by information held</u> |
|--|---|--|
| Contact with Equipment resulting in burns or electric shock | Participants Operators Spectators | All generators/Blowers are to be enclosed in industry standard barrier fencing or Hazard tape and kept at a safe distance All Generators to be earthed using an earth rod |
| Leaking fuel causing fire or slip | Participants Operators Spectators | Generators/ Blowers are serviced and tested annually. Each generator will have its own fire extinguisher. No smoking on and around the inflatable |
| Fire | Participants Operators Spectators | Safety fencing/Barrier to be erected to cordon area off. Suitable Fire extinguisher supplied. Spare Fuel stored in safe container. Unit switched off when refuelling No smoking on and around the inflatable |